



Mayor Robert E. Simison

City Council Members:

Treg Bernt
Joe Borton
Luke Cavener

Brad Hoaglund
Jessica Perreault
Liz Strader

BACKFLOW PREVENTION ASSEMBLY TESTER-PRICE SUBMITTAL AND REQUIREMENTS FORM

2022 TESTING PRICE:

\$ _____ please add current price for FY22 “price is not to include repairs”.

TESTING REQUIREMENTS:

1. Licensure and Equipment Certifications

- a. Submit current Tester Licensure and Equipment Certification with this form. Copies must be on file with the City of Meridian Water Division.
- b. Any status updates pertaining to either must be submitted via email to the City of Meridian Water Division within **fifteen (15)** days at backflow@meridiacity.org.

2. Testing Requirements

- a. All assemblies tested must be tagged with a permanent tag listing the tester’s license number, company, and date of test.
- b. All test ports on double check valve backflow preventers that are installed underground must be plugged with threaded plugs (plastic plugs are OK).
- c. Compliance with IDAPA Rule 650 – Backflow Assembly Tester Code of Ethics and Standards Conduct is required

3. Reporting

- a. All test reports must be accurate, legible and complete.
- b. Falsifying test reports will result in disciplinary action in accordance with IDAPA Rule 650 (enclosed); up to and including a permanent ban on testing within the City of Meridian.
- c. All passing test reports must be received by the City of Meridian Water Division within **fifteen (15)** days of the test date, and failed tests within **two (2)** business days of testing.
- d. Tester must report improper installations found to the Meridian Water Division.
- e. When interconnects between City water and pressurized irrigation are identified, testers are required to report their findings to the Meridian Water Division on the test report.

4. Repairs, Replacement and Installation

- a. All repairs/replacements of failed assemblies must be completed and passing test report submitted to the City of Meridian Water Division within **ten (10)** business days of failed test submittal.
- b. A permit must be obtained from Meridian Building Services prior to replacing a backflow prevention assembly. Meridian Building Services is located on the 1st floor of City Hall, 33 E Broadway Ave, Meridian, ID 83642 (208-887-2211).

I hereby agree to the above requirements and conditions:

Testing Firm

Owner or Agent Printed Name

Signature

Date

Phone

COPY INCLUDED OF BAT LICENSE

COPY INCLUDED OF CALIBRATION FOR ALL TEST KITS

Water Division ■ 2235 N.W. 8th Street, Meridian, ID 83646

Phone 208-888-5242 ■ Fax 208-884-1159 ■ backflow@meridiacity.org ■ www.meridiacity.org